



March 16, 2017

Via E-Mail: Joshua_I_williams@dekalbschoolsga.org

Mr. Joshua L. Williams, MBA, MSM, PMP
Chief Operations Officer
DeKalb County School District
Operations Division
Sam Moss Service Center
1780 Montreal Road
Tucker, Georgia 30084

**Re: Lead in Drinking Water Sample Results
McNair Discovery Learning Academy (Facility ID #0405)
2162 Second Avenue, Decatur, Georgia 30032
AEM Project No. 1561-1601**

Dear Mr. Williams:

Atlanta Environmental Management, Inc. (AEM) is pleased to provide the DeKalb County School District (DCSD) an electronic copy of the Lead in Drinking Water Sample Results for McNair Discovery Learning Academy (Facility ID #0405). Samples were collected on February 28, 2017. Laboratory analytical results were received from Analytical Environmental Services, Inc., on March 14, 2017.

FINDINGS

AEM collected 118 drinking water samples from 59 sources at McNair Discovery Learning Academy (Facility ID #0405), including two duplicate samples. A description of the drinking water outlets sampled and a summary of sample analytical results are provided in the attached table.

None of the samples collected and analyzed contained lead at a concentration equal to or above EPA's action level of 15 parts per billion.

We appreciate your selection of AEM for this project. If you have any questions, please do not hesitate to contact us.

Sincerely,

Atlanta Environmental Management, Inc.

Leona Miles, CHMM
Senior Project Manager

Janet T. Hart
President

/krf

cc: Daniel Drake (DCSD)
Tracee Hill (DCSD)
Sandra Glen (DeKalb County Watershed Management)
Ryan Cira (DeKalb Board of Health)

Attachment: Table

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results
MCNAIR DISCOVERY LEARNING ACADEMY
2162 Second Avenue, Decatur, GA 30032



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0405-022817-DF-001-A	Initial Draw Sample; Left wall-mounted Drinking Fountain leaking from base of fountain Located In Gym	2/28/17 6:04 AM	None Detected
0405-022817-DF-001-B	Flush sample; Left wall-mounted Drinking Fountain leaking from base of fountain Located In Gym	2/28/17 6:05 AM	None Detected
0405-022817-DF-002-A	Initial Draw Sample; Right wall-mounted Drinking Fountain Located In Gym	2/28/17 6:06 AM	None Detected
0405-022817-DF-002-B	Flush sample; Right wall-mounted Drinking Fountain Located In Gym	2/28/17 6:07 AM	None Detected
0405-022817-DF-003-A	Initial Draw Sample; Lower Right Elkay wall-mounted Drinking Fountain Located across from Rm 1123	2/28/17 5:48 AM	None Detected
0405-022817-DF-003-B	Flush sample; Lower Right Elkay wall-mounted Drinking Fountain Located across from Rm 1123	2/28/17 5:49 AM	None Detected
0405-022817-DF-004-A	Initial Draw Sample; Upper Left Elkay wall-mounted Drinking Fountain Located across from Rm 1123	2/28/17 5:50 AM	None Detected
0405-022817-DF-004-B	Flush sample; Upper Left Elkay wall-mounted Drinking Fountain Located across from Rm 1123	2/28/17 5:51 AM	None Detected
0405-022817-DF-006-A	Initial Draw Sample; Lower Right Elkay wall-mounted Drinking Fountain Located Outside Boy's RR near 2nd Grade Hall	2/28/17 5:58 AM	None Detected
0405-022817-DF-006-B	Flush sample; Lower Right Elkay wall-mounted Drinking Fountain Located Outside Boy's RR near 2nd Grade Hall	2/28/17 5:59 AM	None Detected
0405-022817-DF-007-A	Initial Draw Sample; Lower Right Elkay wall-mounted Drinking Fountain Located to the Right of Computer Lab Rm 1155	2/28/17 5:21 AM	None Detected
0405-022817-DF-007-B	Flush sample; Lower Right Elkay wall-mounted Drinking Fountain Located to the Right of Computer Lab Rm 1155	2/28/17 5:22 AM	None Detected
0405-022817-DF-008-A	Initial Draw Sample; Upper Left Elkay wall-mounted Drinking Fountain Located to the Right of Computer Lab Rm 1155	2/28/17 5:23 AM	None Detected
0405-022817-DF-008-B	Flush sample; Upper Left Elkay wall-mounted Drinking Fountain Located to the Right of Computer Lab Rm 1155	2/28/17 5:24 AM	None Detected
0405-022817-DF-009-A	Initial Draw Sample; Upper Left Elkay wall-mounted Drinking Fountain Located Outside Boy's RR near 3rd Grade Hall	2/28/17 6:02 AM	None Detected

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results
MCNAIR DISCOVERY LEARNING ACADEMY
 2162 Second Avenue, Decatur, GA 30032



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0405-022817-DF-009-B	Flush sample; Upper Left Elkay wall-mounted Drinking Fountain Located Outside Boy's RR near 3rd Grade Hall	2/28/17 6:03 AM	None Detected
0405-022817-DF-010-A	Initial Draw Sample; Lower Right Elkay wall-mounted Drinking Fountain Located Outside Boy's RR near 3rd Grade Hall	2/28/17 6:04 AM	None Detected
0405-022817-DF-010-B	Flush sample; Lower Right Elkay wall-mounted Drinking Fountain Located Outside Boy's RR near 3rd Grade Hall	2/28/17 6:05 AM	None Detected
0405-022817-DF-011-A	Initial Draw Sample; Lower Right Elkay wall-mounted Drinking Fountain Located Outside TL Rm 1115	2/28/17 5:31 AM	None Detected
0405-022817-DF-011-B	Flush sample; Lower Right Elkay wall-mounted Drinking Fountain Located Outside TL Rm 1115	2/28/17 5:32 AM	None Detected
0405-022817-DF-012-A	Initial Draw Sample; Lower Right Elkay wall-mounted Drinking Fountain Located Around corner from Rm 2120	2/28/17 5:58 AM	None Detected
0405-022817-DF-012-B	Flush sample; Lower Right Elkay wall-mounted Drinking Fountain Located Around corner from Rm 2120	2/28/17 5:59 AM	None Detected
0405-022817-DF-013-A	Initial Draw Sample; Upper Left Elkay wall-mounted Drinking Fountain Located Across hall from Rm2149	2/28/17 6:07 AM	None Detected
0405-022817-DF-013-B	Flush sample; Upper Left Elkay wall-mounted Drinking Fountain Located Across hall from Rm 2149	2/28/17 6:08 AM	None Detected
0405-022817-DF-014-A	Initial Draw Sample; Lower Right Elkay wall-mounted Drinking Fountain Located Across hall from Rm 2149	2/28/17 6:09 AM	None Detected
0405-022817-DF-014-B	Flush sample; Lower Right Elkay wall-mounted Drinking Fountain Located Across hall from Rm 2149	2/28/17 6:10 AM	None Detected
0405-022817-DF-015-A	Initial Draw Sample; Upper Left Elkay wall-mounted Drinking Fountain Located Next to Rm G140	2/28/17 5:11 AM	None Detected
0405-022817-DF-015-B	Flush sample; Upper Left Elkay wall-mounted Drinking Fountain Located Next to Rm G140	2/28/17 5:12 AM	None Detected
0405-022817-DF-016-A	Initial Draw Sample; Lower Right Elkay wall-mounted Drinking Fountain Located Next to Rm G140	2/28/17 5:13 AM	None Detected

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results
MCNAIR DISCOVERY LEARNING ACADEMY
2162 Second Avenue, Decatur, GA 30032



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0405-022817-DF-016-B	Flush sample; Lower Right Elkay wall-mounted Drinking Fountain Located Next to Rm G140	2/28/17 5:14 AM	None Detected
0405-022817-DF-017-A	Initial Draw Sample; Lower Right Elkay wall-mounted Drinking Fountain Located Next to Ground Floor RR/Rm G132	2/28/17 5:37 AM	None Detected
0405-022817-DF-017-B	Flush sample; Lower Right Elkay wall-mounted Drinking Fountain Located Next to Ground Floor RR/Rm G132	2/28/17 5:38 AM	None Detected
0405-022817-DF-018-A	Initial Draw Sample; Upper Left Elkay wall-mounted Drinking Fountain Located Next to Ground Floor RR/Rm G132	2/28/17 5:35 AM	None Detected
0405-022817-DF-018-B	Flush sample; Upper Left Elkay wall-mounted Drinking Fountain Located Next to Ground Floor RR/Rm G132	2/28/17 5:36 AM	None Detected
0405-022817-DF-019-A	Initial Draw Sample; Upper Left Elkay wall-mounted Drinking Fountain Located In Outside TL RM 1115	2/28/17 5:33 AM	None Detected
0405-022817-DF-019-B	Flush sample; Upper Left Elkay wall-mounted Drinking Fountain Located In Outside TL RM 1115	2/28/17 5:34 AM	None Detected
0405-022817-DF-024-A	Initial Draw Sample; Upper Left Elkay wall-mounted Drinking Fountain Located around corner from Rm 2120	2/28/17 5:56 AM	None Detected
0405-022817-DF-024-B	Flush sample; Upper Left Elkay wall-mounted Drinking Fountain Located around corner from Rm 2120	2/28/17 5:57 AM	None Detected
0405-022817-KS-001-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1179	2/28/17 5:07 AM	None Detected
0405-022817-KS-001-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm1179	2/28/17 5:08 AM	None Detected
0405-022817-KS-002-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1177	2/28/17 5:14 AM	None Detected
0405-022817-KS-002-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1177	2/28/17 5:15 AM	None Detected
0405-022817-KS-003-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm1175	2/28/17 5:20 AM	None Detected

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results

MCNAIR DISCOVERY LEARNING ACADEMY

2162 Second Avenue, Decatur, GA 30032



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0405-022817-KS-003-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1175	2/28/17 5:21 AM	None Detected
0405-022817-KS-004-A	Initial Draw Sample; Kindergarten Sink - Missing handle but still functional Located In Rm 1173	2/28/17 5:27 AM	None Detected
0405-022817-KS-004-B	Flush sample; Kindergarten Sink - Missing handle but still functional Located In Rm 1173	2/28/17 5:28 AM	None Detected
0405-022817-KS-005-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1186	2/28/17 5:10 AM	None Detected
0405-022817-KS-005-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1186	2/28/17 5:11 AM	None Detected
0405-022817-KS-006-A	Initial Draw Sample; Kindergarten Sink - Missing handle but still functional Located In Rm 1184	2/28/17 5:17 AM	None Detected
0405-022817-KS-006-B	Flush sample; Kindergarten Sink - Missing handle but still functional Located In Rm 1184	2/28/17 5:18 AM	None Detected
0405-022817-KS-007-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1182	2/28/17 5:23 AM	None Detected
0405-022817-KS-007-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1182	2/28/17 5:24 AM	None Detected
0405-022817-KS-008-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1180	2/28/17 5:29 AM	None Detected
0405-022817-KS-008-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1180	2/28/17 5:30 AM	None Detected
0405-022817-KS-010-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1199	2/28/17 5:46 AM	1.24
0405-022817-KS-010-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1199	2/28/17 5:47 AM	None Detected
0405-022817-KS-011-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1197	2/28/17 5:49 AM	None Detected

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results

MCNAIR DISCOVERY LEARNING ACADEMY

2162 Second Avenue, Decatur, GA 30032



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0405-022817-KS-011-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1197	2/28/17 5:50 AM	None Detected
0405-022817-KS-012-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1195	2/28/17 5:40 AM	1.67
0405-022817-KS-012-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1195	2/28/17 5:41 AM	None Detected
0405-022817-KS-014-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1206	2/28/17 5:36 AM	None Detected
0405-022817-KS-014-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1206	2/28/17 5:37 AM	None Detected
0405-022817-KS-015-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1204	2/28/17 5:35 AM	None Detected
0405-022817-KS-015-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1204	2/28/17 5:36 AM	None Detected
0405-022817-KS-016-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1202	2/28/17 5:43 AM	None Detected
0405-022817-KS-016-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm 1202	2/28/17 5:44 AM	None Detected
0405-022817-KS-017-A	Initial Draw Sample; Kindergarten Sink - Restroom Sink, TL Located In Rm 1200	2/28/17 5:46 AM	None Detected
0405-022817-KS-017-B	Flush sample; Kindergarten Sink - Restroom Sink, TL Located In Rm 1200	2/28/17 5:47 AM	None Detected
0405-022817-KS-018-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G115	2/28/17 5:27 AM	None Detected
0405-022817-KS-018-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G115	2/28/17 5:28 AM	None Detected
0405-022817-KS-019-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G113	2/28/17 5:17 AM	None Detected
0405-022817-KS-019-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G113	2/28/17 5:18 AM	None Detected

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results

MCNAIR DISCOVERY LEARNING ACADEMY

2162 Second Avenue, Decatur, GA 30032



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0405-022817-KS-020-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G111	2/28/17 5:15 AM	None Detected
0405-022817-KS-020-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G111	2/28/17 5:16 AM	None Detected
0405-022817-KS-021-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G109	2/28/17 5:27 AM	None Detected
0405-022817-KS-021-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G109	2/28/17 5:28 AM	None Detected
0405-022817-KS-022-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G148	2/28/17 5:25 AM	None Detected
0405-022817-KS-022-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G148	2/28/17 5:26 AM	None Detected
0405-022817-KS-023-A	Initial Draw Sample, Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G146	2/28/17 5:22 AM	None Detected
0405-022817-KS-023-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G146	2/28/17 5:23 AM	None Detected
0405-022817-KS-024-A	Initial Draw Sample, Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G144	2/28/17 5:10 AM	None Detected
0405-022817-KS-024-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G144	2/28/17 5:11 AM	None Detected
0405-022817-KS-025-A	Initial Draw Sample, Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G142	2/28/17 5:24 AM	None Detected
0405-022817-KS-025-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G142	2/28/17 5:25 AM	None Detected
0405-022817-KS-026-A	Initial Draw Sample, Kindergarten Sink - Only Sink in Room Was RR sink Located In Rm G140	2/28/17 5:20 AM	None Detected
0405-022817-KS-026-B	Flush sample; Kindergarten Sink - Only Sink in Room Was RR sink Located In Rm G140	2/28/17 5:21 AM	None Detected

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results

MCNAIR DISCOVERY LEARNING ACADEMY

2162 Second Avenue, Decatur, GA 30032



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0405-022817-KS-027-A	Initial Draw Sample, Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G151	2/28/17 6:07 AM	None Detected
0405-022817-KS-027-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G151	2/28/17 6:08 AM	None Detected
0405-022817-KS-028-A	Initial Draw Sample, Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G149	2/28/17 6:03 AM	None Detected
0405-022817-KS-028-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G149	2/28/17 6:04 AM	None Detected
0405-022817-KS-029-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G147	2/28/17 5:56 AM	None Detected
0405-022817-KS-029-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G147	2/28/17 5:57 AM	None Detected
0405-022817-KS-030-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G145	2/28/17 5:47 AM	None Detected
0405-022817-KS-030-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G145	2/28/17 5:48 AM	None Detected
0405-022817-KS-031-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G160	2/28/17 6:09 AM	None Detected
0405-022817-KS-031-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G160	2/28/17 6:10 AM	None Detected
0405-022817-KS-032-A	Initial Draw Sample, Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G158	2/28/17 6:05 AM	None Detected
0405-022817-KS-032-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G158	2/28/17 6:06 AM	None Detected
0405-022817-KS-033-A	Initial Draw Sample, Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G156	2/28/17 5:58 AM	None Detected
0405-022817-KS-033-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In RmG156	2/28/17 5:59 AM	None Detected

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results
MCNAIR DISCOVERY LEARNING ACADEMY
 2162 Second Avenue, Decatur, GA 30032



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0405-022817-KS-034-A	Initial Draw Sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G154	2/28/17 5:45 AM	None Detected
0405-022817-KS-034-B	Flush sample; Kindergarten Sink - Sink W/ Bubbler, Sampled Faucet Located In Rm G154	2/28/17 5:46 AM	None Detected
0405-022817-RS-001-A	Initial Draw Sample; Restroom Sink - Only sink in Girls RR in Gym	2/28/17 6:11 AM	None Detected
0405-022817-RS-001-B	Flush sample; Restroom Sink - Only sink in Girls RR in Gym	2/28/17 6:13 AM	None Detected
0405-022817-RS-002-A	Initial Draw Sample; Restroom Sink - Middle Sink in Boy's RR/Rm G132	2/28/17 5:39 AM	None Detected
0405-022817-RS-002-B	Flush sample; Restroom Sink - Middle Sink in Boy's RR/Rm G132	2/28/17 5:40 AM	None Detected
0405-022817-RS-003-A	Initial Draw Sample; Restroom Sink - Far Right Sink in Girl's RR/Rm 2117	2/28/17 6:02 AM	None Detected
0405-022817-RS-003-B	Flush sample; Restroom Sink - Far Right Sink in Girl's RR/Rm 2117	2/28/17 6:03 AM	None Detected
0405-022817-TL-001-A	Initial Draw Sample; Teacher's Lounge - Only sink in Rm 1107	2/28/17 5:43 AM	None Detected
0405-022817-TL-001-B	Flush sample; Teacher's Lounge - Only sink in Rm 1107	2/28/17 5:44 AM	None Detected
0405-022817-TL-002-A	Initial Draw Sample; Teacher's Lounge - Sink To the Left of Fridge Located In Rm 1115	2/28/17 5:38 AM	None Detected
0405-022817-TL-002-B	Flush sample; Teacher's Lounge - Sink To the Left of Fridge Located In Rm 1115	2/28/17 5:39 AM	None Detected
0405-022817-CS-001-A	Initial Draw Sample; Cafeteria Sink - Produce Salad sink Located In Kitchen	2/28/17 5:10 AM	2.86
0405-022817-CS-001-B	Flush sample; Cafeteria Sink - Produce Salad sink Located In Kitchen	2/28/17 5:11 AM	None Detected
0405-022817-IM-001-A	Initial Draw Sample; Scotsman Ice Machine Located In Kitchen, near the front	2/28/17 5:15 AM	None Detected
0405-022817-SC-001-A	Service Connection Entry into Building	2/28/17 4:57 AM	**

Notes:

ppb-parts per billion

Bold-Exceeds 15 ppb--EPA's Action Level for Lead

* Note--Where "A" and "B" are indicated, AEM collected two samples at each source area location: ("A") initial draw sample; and ("B") after a 30-second flush sample

**Inconclusive Sample Result; Retesting is underway