



November 20, 2017

Via E-Mail: Joshua_I_williams@dekalbschoolsga.org

Mr. Joshua L. Williams, MBA, MSM, PMP
Chief Operations Officer
DeKalb County School District
Operations Division
Sam Moss Service Center
1780 Montreal Road
Tucker, Georgia 30084

**Re: Summary of Additional Lead in Drinking Water Sample Results
Wynbrooke Elementary School (Facility ID #0102)
440 Wicksbury Way, Stone Mountain, Georgia 30087
AEM Project No. 1561-1601**

Dear Mr. Williams:

Atlanta Environmental Management, Inc. (AEM) is pleased to provide the DeKalb County School District (DCSD) an electronic copy of the Lead in Drinking Water Sample Results for Wynbrooke Elementary School (Facility ID #0102). Additional drinking water samples from select source units were collected on October 4, 2017, and November 9, 2017, and analytical results were received from Analytical Environmental Services, Inc., on October 13, 2017, and November 17, 2017.

FINDINGS

Sample Results of Previously Identified Source Units That Exceeded 15 ppb

During the initial sampling event on March 2, 2017, three source units were sampled and the analytical results indicated that the results were above EPA's action level of 15 parts per billion (ppb). DCSD replaced the units and AEM collected six drinking water samples on October 4, 2017. None of the samples collected from source units KS-015 and KS-020 contained lead at a concentration exceeding EPA's action level of 15 ppb.

One or more of the samples collected from OT-001 contained lead at a concentration exceeding EPA's action level of 15 ppb. This unit remained out of service to evaluate additional remediation alternatives.

A filter was added to the faucet of OT-001 and AEM collected two drinking water samples on November 9, 2017. None of the samples collected contained lead at a concentration at or above EPA's action level of 15 ppb.

A description of the drinking water outlet sampled and a summary of sample analytical results are provided in Table 1.


We appreciate your selection of AEM for this project. If you have any questions, please do not hesitate to contact us.

Sincerely,

Atlanta Environmental Management, Inc.



Leona Miles, CHMM
Senior Project Manager



Janet T. Hart
President

/krf

cc: Daniel Drake (DCSD)
Tracee Hill (DCSD)
Sandra Glenn (DeKalb County Watershed Management)
Ryan Cira (DeKalb Board of Health)

Attachment: Table

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Retest Results

Wynbrooke Elementary School
 440 Wicksbury Way, Stone Mountain, GA 30087



Sample ID ^{*/**}	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0102-100417-KS-015-A	Initial Draw Sample; Retest Sink W/ Bubbler; Sampled Faucet located in RM 465	10/4/17 5:30 AM	1.92
0102-100417-KS-015-B	Flush sample; Retest Sink W/ Bubbler; Sampled Faucet located in RM 465	10/4/17 5:31 AM	None Detected
0102-100417-KS-020-A	Initial Draw Sample; Retest Sink W/ Bubbler; Sampled Faucet located in RM 468	10/4/17 5:24 AM	1.89
0102-100417-KS-020-B	Flush sample; Retest Sink W/ Bubbler; Sampled Faucet located in RM 468	10/4/17 5:25 AM	None Detected
0102-110917-OT-001-A	Initial Draw Sample; Retest Sink at center of classroom located in RM 337; filter added	11/9/17 5:54 AM	3.19
0102-110917-OT-001-B	Flush sample; Retest Sink at center of classroom located in RM 337; filter added	11/9/17 5:55 AM	None Detected

Notes:

ppb-parts per billion

Bold-Exceeds 15 ppb--EPA's Action Level for Lead

* Note--Where "A" and "B" are indicated, AEM collected two samples at each source area location: ("A") initial draw sample; and ("B") after a 30-second flush sample

**The source units were initially sampled on 3/2/17 and the initial results indicated that a concentration exceeded the EPA standard of 15 ppb. The source units were replaced and/or a filter was installed by DCSD and retesting was conducted. The above summarizes the retest results.



March 17, 2017

Via E-Mail: Joshua_I_williams@dekalbschoolsga.org

Mr. Joshua L. Williams, MBA, MSM, PMP
Chief Operations Officer
DeKalb County School District
Operations Division
Sam Moss Service Center
1780 Montreal Road
Tucker, Georgia 30084

**Re: Lead in Drinking Water Sample Results
Wynbrooke Elementary School (Facility ID #0102)
440 Wicksbury Way, Stone Mountain, Georgia 30087
AEM Project No. 1561-1601**

Dear Mr. Williams:

Atlanta Environmental Management, Inc. (AEM) is pleased to provide the DeKalb County School District (DCSD) an electronic copy of the Lead in Drinking Water Sample Results for Wynbrooke Elementary School (Facility ID #0102). Samples were collected on March 2, 2017, and analytical results were received from Analytical Environmental Services, Inc., on March 16, 2017.

FINDINGS


AEM collected 164 drinking water samples from 82 sources at Wynbrooke Elementary School (Facility ID #0102), including two duplicate samples. A description of the drinking water outlets sampled and a summary of sample analytical results are provided in the attached table.

Three of the sources sampled had a drinking water sample result that contained lead at a concentration at or above EPA's action level of 15 parts per billion. These sources are indicated in bold and shaded font in the attached table.

We appreciate your selection of AEM for this project. If you have any questions, please do not hesitate to contact us.

Sincerely,

Atlanta Environmental Management, Inc.



Leona Miles, CHMM
Senior Project Manager



Janet T. Hart
President

/krf

cc: Daniel Drake (DCSD)
Tracee Hill (DCSD)
Sandra Glenn (DeKalb County Watershed Management)
Ryan Cira (DeKalb Board of Health)

Attachment: Table

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results

Wynbrooke Elementary School
440 Wicksbury Way, Stone Mountain, GA 30087



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0102-030217-DF-001-A	Initial Draw Sample, Single Elkay wall-mounted Drinking Fountain located in Gym	3/2/17 5:55 AM	None Detected
0102-030217-DF-001-B	Flush sample; Single Elkay wall-mounted Drinking Fountain located in Gym	3/2/17 5:56 AM	None Detected
0102-030217-DF-002-A	Initial Draw Sample, Lower Left Oasis wall-mounted Drinking Fountain located to the right of RM 218	3/2/17 5:49 AM	None Detected
0102-030217-DF-002-B	Flush sample; Lower Left Oasis wall-mounted Drinking Fountain located to the right of RM 218	3/2/17 5:50 AM	None Detected
0102-030217-DF-003-A	Initial Draw Sample; Upper Right Oasis wall-mounted Drinking Fountain located to the right of RM 218	3/2/17 5:51 AM	None Detected
0102-030217-DF-003-B	Flush sample; Upper Right Oasis wall-mounted Drinking Fountain located to the right of RM 218	3/2/17 5:52 AM	None Detected
0102-030217-DF-004-A	Initial Draw Sample, Lower Left Oasis wall-mounted Drinking Fountain located to the left of RM 311	3/2/17 6:02 AM	None Detected
0102-030217-DF-004-B	Flush sample; Lower Left Oasis wall-mounted Drinking Fountain located to the left of RM 311	3/2/17 6:03 AM	None Detected
0102-030217-DF-005-A	Initial Draw Sample; Upper Right Oasis wall-mounted Drinking Fountain located to the left of RM 311	3/2/17 6:04 AM	None Detected
0102-030217-DF-005-B	Flush sample; Upper Right Oasis wall-mounted located to the left of RM 311	3/2/17 6:05 AM	None Detected
0102-030217-DF-006-A	Initial Draw Sample, Left Set Lower Left Oasis wall-mounted Drinking Fountain located to the left of RM 335	3/2/17 5:26 AM	None Detected
0102-030217-DF-006-B	Flush, Left Set Lower Left Oasis wall-mounted Drinking Fountain located to the left of RM 335	3/2/17 5:27 AM	None Detected
0102-030217-DF-007-A	Initial Draw Sample; Left Set Upper Right Oasis wall-mounted Drinking Fountain located to the left of RM 335	3/2/17 5:28 AM	None Detected
0102-030217-DF-007-B	Flush sample; Left Set Upper Right Oasis wall-mounted located to the left of RM 335	3/2/17 5:29 AM	None Detected
0102-030217-DF-008-A	Initial Draw Sample, Right Set Lower Left Oasis wall-mounted Drinking Fountain located to the left of RM 335	3/2/17 5:30 AM	None Detected

**Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results
Wynbrooke Elementary School
440 Wicksbury Way, Stone Mountain, GA 30087**



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0102-030217-DF-008-B	Flush sample; Right Set Lower Left Oasis wall-mounted Drinking Fountain located to the left of RM 335	3/2/17 5:31 AM	None Detected
0102-030217-DF-009-A	Initial Draw Sample, right Set Upper Right Oasis wall-mounted Drinking Fountain located to the left of RM 335	3/2/17 5:32 AM	None Detected
0102-030217-DF-009-B	Flush sample; Right Set Upper Right Oasis wall-mounted Drinking Fountain located to the left of RM 335	3/2/17 5:33 AM	None Detected
0102-030217-DF-010-A	Initial Draw Sample; Single Elkay wall-mounted Drinking Fountain located to the left of RM 510	3/2/17 5:56 AM	None Detected
0102-030217-DF-010-B	Flush sample; Single Elkay wall-mounted Drinking Fountain located to the left of RM 510	3/2/17 5:57 AM	None Detected
0102-030217-DF-011-A	Initial Draw Sample; Lower Left Oasis wall-mounted Drinking Fountain located to the right of RM 560	3/2/17 5:14 AM	None Detected
0102-030217-DF-011-B	Flush sample; Lower Left Oasis wall-mounted Drinking Fountain located to the right of RM 560	3/2/17 5:15 AM	None Detected
0102-030217-DF-012-A	Initial Draw Sample; Upper Right Oasis wall-mounted Drinking Fountain located to the right of RM 560	3/2/17 5:16 AM	None Detected
0102-030217-DF-012-B	Flush sample; Upper Right Oasis wall-mounted Drinking Fountain located to the right of RM 560	3/2/17 5:17 AM	None Detected
0102-030217-DF-013-A	Initial Draw Sample; Right Pair Of Drinking Fountains - Upper Right Elkay wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:33 AM	4.01
0102-030217-DF-013-B	Flush sample; Right Pair Of Drinking Fountains - Upper Right Elkay wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:34 AM	2.36
0102-030217-DF-014-A	Initial Draw Sample; Right Pair of Drinking Fountains- Lower Left Elkay wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:35 AM	4.06
0102-030217-DF-014-B	Flush sample; Right Pair of Drinking Fountains - Lower Left Elkay wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:36 AM	1.52
0102-030217-DF-015-A	Initial Draw Sample; Middle Pair of Drinking Fountains - Upper Right Elkay wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:37 AM	None Detected

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results

Wynbrooke Elementary School
440 Wicksbury Way, Stone Mountain, GA 30087



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0102-030217-DF-015-B	Flush sample; Middle Pair of Drinking Fountains - Upper Right Elkay wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:38 AM	None Detected
0102-030217-DF-016-A	Initial Draw Sample; Middle Pair of Drinking Fountains - Lower Left Elkay wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:39 AM	None Detected
0102-030217-DF-016-B	Flush sample; Middle Pair of Drinking Fountains - Lower Left Elkay wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:40 AM	None Detected
0102-030217-DF-017-A	Initial Draw Sample; Left Pair of Drinking Fountains- Upper Right Oasis wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:41 AM	None Detected
0102-030217-DF-017-B	Flush sample; Left Pair of Drinking Fountains - Upper Right Oasis wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:42 AM	None Detected
0102-030217-DF-018-A	Initial Draw Sample; Left Pair of Drinking Fountains- Lower Left Oasis wall-mounted Drinking Fountain located to the left of RM 469	3/2/17 5:43 AM	None Detected
0102-030217-DF-018-B	Flush, Left Pair, Lower Left Oasis wall-mounted located to the left of RM 469	3/2/17 5:44 AM	None Detected
0102-030217-DF-019-A	Initial Draw Sample; Far right Pair of Drinking Fountains-Upper Right Oasis wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:05 AM	None Detected
0102-030217-DF-019-B	Flush sample; Far right Pair of Drinking Fountains-Upper Right Oasis wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:06 AM	None Detected
0102-030217-DF-020-A	Initial Draw Sample; Far right Pair of Drinking Fountains-Lower Left Oasis wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:07 AM	None Detected
0102-030217-DF-020-B	Flush sample; Far right Pair of Drinking Fountains-Lower Left Oasis wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:08 AM	None Detected
0102-030217-DF-021-A	Initial Draw Sample; Middle Pair of Drinking Fountains-Upper Right Elkay wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:09 AM	None Detected
0102-030217-DF-021-B	Flush sample; Middle Pair of Drinking Fountains-Upper Right Elkay wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:10 AM	None Detected
0102-030217-DF-022-A	Initial Draw Sample; Middle Pair of Drinking Fountains-Lower Left Elkay wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:11 AM	None Detected

**Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results
Wynbrooke Elementary School
440 Wicksbury Way, Stone Mountain, GA 30087**



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0102-030217-DF-022-B	Flush sample; Middle Pair of Drinking Fountains-Lower Left Elkay wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:12 AM	None Detected
0102-030217-DF-023-A	Initial Draw Sample; Far Left Pair of Drinking Fountains-Upper Right Oasis wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:13 AM	None Detected
0102-030217-DF-023-B	Flush sample; Far Left Pair of Drinking Fountains-Upper Right Oasis wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:14 AM	None Detected
0102-030217-DF-024-A	Initial Draw Sample; Far Left Pair of Drinking Fountains-Lower Left Oasis wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:15 AM	None Detected
0102-030217-DF-024-B	Flush sample; Far Left Pair of Drinking Fountains-Lower Left Oasis wall-mounted Drinking Fountain located Next to 422 Work Room	3/2/17 6:16 AM	None Detected
0102-030217-DF-025-A	Initial Draw Sample; Lower Left Oasis wall-mounted Drinking Fountain located in Cafeteria	3/2/17 5:42 AM	None Detected
0102-030217-DF-025-B	Flush sample; Lower Left Oasis wall-mounted Drinking Fountain located in Cafeteria	3/2/17 5:43 AM	None Detected
0102-030217-DF-026-A	Initial Draw Sample; Upper Right Oasis wall-mounted Drinking Fountain located in Cafeteria	3/2/17 5:44 AM	None Detected
0102-030217-DF-026-B	Flush sample; Upper Right Oasis wall-mounted Drinking Fountain located in Cafeteria	3/2/17 5:45 AM	None Detected
0102-030217-KS-001-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 415	3/2/17 5:05 AM	None Detected
0102-030217-KS-001-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 415	3/2/17 5:06 AM	None Detected
0102-030217-KS-002-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 416	3/2/17 5:08 AM	None Detected
0102-030217-KS-002-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 416	3/2/17 5:09 AM	None Detected
0102-030217-KS-003-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 414	3/2/17 5:10 AM	None Detected
0102-030217-KS-003-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 414	3/2/17 5:11 AM	None Detected
0102-030217-KS-004-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 417	3/2/17 5:13 AM	None Detected
0102-030217-KS-004-B	Flush Sample; Sink W/ Bubbler; Sampled Faucet located in RM 417	3/2/17 5:14 AM	None Detected
0102-030217-KS-005-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 413	3/2/17 5:16 AM	None Detected
0102-030217-KS-005-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 413	3/2/17 5:17 AM	None Detected
0102-030217-KS-006-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 418	3/2/17 5:20 AM	None Detected

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results

Wynbrooke Elementary School
440 Wicksbury Way, Stone Mountain, GA 30087



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0102-030217-KS-006-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 418	3/2/17 5:21 AM	None Detected
0102-030217-KS-007-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 412	3/2/17 5:23 AM	None Detected
0102-030217-KS-007-B	Flush; Sink W/ Bubbler; Sampled Faucet located in RM 412	3/2/17 5:24 AM	None Detected
0102-030217-KS-008-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 419	3/2/17 5:26 AM	None Detected
0102-030217-KS-008-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 419	3/2/17 5:27 AM	None Detected
0102-030217-KS-009-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 403	3/2/17 5:34 AM	None Detected
0102-030217-KS-009-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 403	3/2/17 5:35 AM	None Detected
0102-030217-KS-010-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 425	3/2/17 5:36 AM	None Detected
0102-030217-KS-010-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 425	3/2/17 5:37 AM	None Detected
0102-030217-KS-011-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 402	3/2/17 5:40 AM	4.33
0102-030217-KS-011-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 402	3/2/17 5:41 AM	None Detected
0102-030217-KS-012-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 426	3/2/17 5:45 AM	None Detected
0102-030217-KS-012-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 426	3/2/17 5:46 AM	None Detected
0102-030217-KS-013-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 401	3/2/17 5:48 AM	None Detected
0102-030217-KS-013-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 401	3/2/17 5:49 AM	1.29
0102-030217-KS-014-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 427	3/2/17 5:50 AM	4.67
0102-030217-KS-014-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 427	3/2/17 5:51 AM	4.80
0102-030217-KS-015-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 465	3/2/17 6:06 AM	209
0102-030217-KS-015-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 465	3/2/17 6:07 AM	2.78
0102-030217-KS-016-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 466	3/2/17 6:04 AM	None Detected
0102-030217-KS-016-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 466	3/2/17 6:05 AM	None Detected
0102-030217-KS-017-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 464	3/2/17 6:00 AM	1.06
0102-030217-KS-017-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 464	3/2/17 6:01 AM	1.20
0102-030217-KS-018-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 467	3/2/17 6:02 AM	2.18
0102-030217-KS-018-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 467	3/2/17 6:03 AM	6.27
0102-030217-KS-019-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 463	3/2/17 5:52 AM	None Detected
0102-030217-KS-019-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 463	3/2/17 5:53 AM	None Detected
0102-030217-KS-020-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 468	3/2/17 5:55 AM	50.6
0102-030217-KS-020-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 468	3/2/17 5:56 AM	22.8

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results
Wynbrooke Elementary School
440 Wicksbury Way, Stone Mountain, GA 30087



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0102-030217-KS-021-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 462	3/2/17 5:48 AM	1.54
0102-030217-KS-021-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 462	3/2/17 5:49 AM	None Detected
0102-030217-KS-022-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 469	3/2/17 5:50 AM	None Detected
0102-030217-KS-022-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 469	3/2/17 5:51 AM	None Detected
0102-030217-KS-023-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 455	3/2/17 5:19 AM	None Detected
0102-030217-KS-023-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 455	3/2/17 5:20 AM	None Detected
0102-030217-KS-024-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 473; sink dripping on arrival	3/2/17 5:09 AM	None Detected
0102-030217-KS-024-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 473; sink dripping on arrival	3/2/17 5:10 AM	None Detected
0102-030217-KS-025-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 454	3/2/17 5:06 AM	None Detected
0102-030217-KS-025-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 454	3/2/17 5:07 AM	None Detected
0102-030217-KS-026-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 453	3/2/17 5:00 AM	None Detected
0102-030217-KS-026-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 453	3/2/17 5:01 AM	None Detected
0102-030217-KS-027-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 475	3/2/17 5:03 AM	None Detected
0102-030217-KS-027-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 475	3/2/17 5:04 AM	None Detected
0102-030217-KS-028-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 452	3/2/17 6:12 AM	8.03
0102-030217-KS-028-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 452	3/2/17 6:13 AM	5.86
0102-030217-KS-029-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 476	3/2/17 6:14 AM	None Detected
0102-030217-KS-029-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 476	3/2/17 6:15 AM	None Detected
0102-030217-KS-030-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in Rm 508	3/2/17 5:41 AM	None Detected
0102-030217-KS-030-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in Rm 508	3/2/17 5:42 AM	None Detected
0102-030217-KS-031-A	Initial Draw Sample, Sink W/ Bubbler Sampled Faucet located in RM 509	3/2/17 5:46 AM	None Detected
0102-030217-KS-031-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 509	3/2/17 5:47 AM	None Detected
0102-030217-KS-032-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 507	3/2/17 6:05 AM	1.06
0102-030217-KS-032-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 507	3/2/17 6:06 AM	None Detected
0102-030217-KS-033-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 510	3/2/17 5:51 AM	None Detected
0102-030217-KS-033-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 510	3/2/17 5:52 AM	None Detected
0102-030217-KS-034-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 513	3/2/17 5:58 AM	None Detected

Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results

Wynbrooke Elementary School
440 Wicksbury Way, Stone Mountain, GA 30087



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0102-030217-KS-034-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 513	3/2/17 5:59 AM	None Detected
0102-030217-KS-035-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 564	3/2/17 5:00 AM	None Detected
0102-030217-KS-035-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 564	3/2/17 5:01 AM	None Detected
0102-030217-KS-036-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 565	3/2/17 5:02 AM	None Detected
0102-030217-KS-036-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 565	3/2/17 5:03 AM	None Detected
0102-030217-KS-037-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 560	3/2/17 5:07 AM	1.60
0102-030217-KS-037-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 560	3/2/17 5:08 AM	None Detected
0102-030217-KS-038-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 569	3/2/17 5:09 AM	None Detected
0102-030217-KS-038-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 569	3/2/17 5:10 AM	None Detected
0102-030217-KS-039-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 556	3/2/17 5:21 AM	1.12
0102-030217-KS-039-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 556	3/2/17 5:22 AM	None Detected
0102-030217-KS-040-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 573	3/2/17 5:23 AM	None Detected
0102-030217-KS-040-B	Flush, Sink W/ Bubbler; Sampled Faucet located in RM 573	3/2/17 5:25 AM	None Detected
0102-030217-KS-041-A	Initial Draw Sample, Sink W/ Bubbler; Sampled Faucet located in RM 552	3/2/17 5:28 AM	4.26
0102-030217-KS-041-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 552	3/2/17 5:29 AM	None Detected
0102-030217-KS-042-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 577	3/2/17 5:30 AM	None Detected
0102-030217-KS-042-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 577	3/2/17 5:31 AM	None Detected
0102-030217-KS-043-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 474	3/2/17 5:14 AM	None Detected
0102-030217-KS-043-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 474	3/2/17 5:15 AM	None Detected
0102-030217-KS-044-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 501	3/2/17 6:09 AM	None Detected
0102-030217-KS-044-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 501	3/2/17 6:10 AM	None Detected
0102-030217-RS-001-A	Initial Draw Sample; Automatic Sink W/ Bubbler; Sampled Faucet located at front of Girls RR next to RM 510	3/2/17 5:54 AM	None Detected

**Table 1. Summary of Lead in Drinking Water Laboratory Analytical Results
Wynbrooke Elementary School
440 Wicksbury Way, Stone Mountain, GA 30087**



Sample ID*	Sample Location Description	Sample Date & Time	Lead Test Results (ppb)
0102-030217-RS-001-B	Flush sample; Automatic Sink W/ Bubbler; Sampled Faucet located at front of Girls RR next to RM 510	3/2/17 5:55 AM	None Detected
0102-030217-TL-001-A	Initial Draw Sample; Only Sink in Room located in RM 108	3/2/17 5:19 AM	None Detected
0102-030217-TL-001-B	Flush sample; Only Sink in Room located in RM 108	3/2/17 5:20 AM	None Detected
0102-030217-TL-002-A	Initial Draw Sample; Only Sink in Room located in RM 321	3/2/17 6:08 AM	None Detected
0102-030217-TL-002-B	Flush sample; Only Sink in Room located in RM 321	3/2/17 6:09 AM	None Detected
0102-030217-TL-003-A	Initial Draw Sample; Only Sink in Room located in RM 336	3/2/17 5:35 AM	None Detected
0102-030217-TL-003-B	Flush sample; Only Sink in Room located in RM 336	3/2/17 5:36 AM	None Detected
0102-030217-TL-004-A	Initial Draw Sample; Sink W/ Bubbler; Sampled Faucet located in RM 422	3/2/17 5:55 AM	1.25
0102-030217-TL-004-B	Flush sample; Sink W/ Bubbler; Sampled Faucet located in RM 422	3/2/17 5:56 AM	None Detected
0102-030217-OT-001-A	Initial Draw Sample; Sink at center of classroom located in RM 337	3/2/17 5:39 AM	40.0
0102-030217-OT-001-B	Flush sample; Sink at center of classroom located in RM 337	3/2/17 5:40 AM	3.96
0102-030217-OT-002-A	Initial Draw Sample; Sink on Left against wall located in RM 337	3/2/17 5:37 AM	None Detected
0102-030217-OT-002-B	Flush sample; Sink on Left against wall located in RM 337	3/2/17 5:38 AM	None Detected
0102-030217-OT-003-A	Initial Draw Sample; Sink on Right against wall located in RM 337	3/2/17 5:35 AM	None Detected
0102-030217-OT-003-B	Flush sample; Sink on Right against wall located in RM 337	3/2/17 5:36 AM	None Detected
0102-030217-OT-004-A	Initial Draw Sample; Sink in counter located in Clinic 115	3/2/17 5:14 AM	None Detected
0102-030217-OT-004-B	Flush sample; Sink in counter located in Clinic 115	3/2/17 5:15 AM	None Detected
0102-030217-CS-001-A	Initial Draw Sample; Food prep sink dripping on arrival located in Kitchen	3/2/17 5:03 AM	2.03
0102-030217-CS-001-B	Flush sample; Food prep sink dripping on arrival located in Kitchen	3/2/17 5:04 AM	None Detected
0102-030217-IM-001-A	Initial Draw Sample; Manitowac Ice Machine located in Kitchen	3/2/17 5:07 AM	None Detected
0102-030217-SC-001-A	Service Connection Entry into Building	3/2/17 4:53 AM	None Detected

Notes:

ppb-parts per billion

Bold-Exceeds 15 ppb--EPA's Action Level for Lead

* Note--Where "A" and "B" are indicated, AEM collected two samples at each source area location: ("A") initial draw sample; and ("B") after a 30-second flush sample